

Consumer Confidence Report

Marine Corps Air Station Iwakuni

Main Base, Atago & Monzen Drinking Water System



This report reflects monitoring data collected in January-June 2022 and will be updated biannually.

Marine Corps Air Station (MCAS) Iwakuni is pleased to provide you with this annual Consumer Confidence Report (CCR) for the Drinking Water System which supports MCAS Iwakuni, Japan. This report provides information about the water delivered to MCAS Iwakuni in January-June 2022. It describes where your water comes from, what it contains, and how it compares to standards for safe drinking water.

Our goal is to provide safe and dependable drinking water. During the period reported in 2022, drinking water at MCAS Iwakuni met all Japan Environmental Governing Standards (JEGS) drinking water health standards.

Source of Water

The source of the drinking water at MCAS Iwakuni is the Nishiki River. The raw water is treated at the Nishimi Water Purification Plant, run by the Iwakuni City Waterworks, and then conveyed via pipelines to MCAS Iwakuni. The plant employs full conventional water treatment including chemical coagulation, flocculation, sedimentation, filtration, and disinfection (chlorination). The Nishimi Water Purification Plant provides MCAS Iwakuni data on the raw water processed by the plant, as well as the finished water it sends to the installation for human consumption. Pump stations on the North, South, Monzen, and Atago areas of the base distribute the water throughout the MCAS Iwakuni distribution system.

Drinking Water Standards

Our drinking water is required to meet the water quality standards established in the Japan Environmental Governing Standards (JEGS). The JEGS are Department of Defense (DoD) governing standards intended to ensure DoD activities and installations in Japan protect human health and the environment, and to ensure safe drinking water is provided to all DoD

personnel and their families.

To continually ensure that our water is safe to drink, the JEGS require us to regularly monitor and test our water for contaminants. MCAS Iwakuni vigilantly safeguards its water supplies and we received the results of recent testing. We are proud to report that our system did not violate any JEGS maximum contaminant levels (MCLs) during this reported period of 2022.

Possible Source of Contaminants

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791), or visiting the EPA website at <https://www.epa.gov/dwstandardsregulations>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Potential Contaminants in Drinking Water

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring, or be the result of oil and gas production and mining activities.

Other Potential Contaminants (Lead)

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. MCAS Iwakuni routinely monitors and tests the water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water Information on lead in drinking water, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Special Health Considerations

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency/Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

What are per- and polyfluoroalkyl substances and where do they come from?

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industries and consumer products around the globe, including in the United States, since the 1940s. PFAS have been used to make coatings and products that are used as oil and water repellents for carpets, clothing, paper packaging for food, and cookware. They are also contained in some foams (aqueous film-forming foam or AFFF) used for fighting petroleum fires at airfields and in industrial fire suppression processes because they rapidly extinguish fires, saving lives and protecting property. PFAS chemicals are persistent in the environment and some are persistent in the human body – meaning they do not break down and they can accumulate over time.

Is there a regulation for PFAS in drinking water?

There is currently no established federal water quality regulation for any PFAS compounds. In June 2022 the EPA released four revised drinking water health advisories for per- and polyfluoroalkyl substances (PFAS), EPA’s lifetime health advisory levels, measured in parts per trillion (ppt), offer protection for people from adverse health effects resulting from exposure throughout their lives to these individual PFAS in drinking water:

- Interim updated health advisory for PFOA = 0.004 ppt
- Interim updated health advisory for PFOS = 0.02 ppt
- Final health advisory for GenX chemicals = 10 ppt
- Final health advisory for PFBS = 2,000 ppt

<https://www.epa.gov/sdwa/questions-and-answers-drinking-water-health-advisories-pfoa-pfos-genx-chemicals-and-pfbs#:~:text=EPA%E2%80%99s%20lifetime%20health%20advisory%20levels%2C%20measured%20in%20parts,updated%20health%20advisory%20for%20PFOS%20%3D%200.02%20ppt>

Out of an abundance of caution for your safety, the Department of Defense’s PFAS testing and response actions go beyond EPA Safe Drinking Water Act requirements. In 2020 the DoD promulgated a policy to monitor drinking water for PFAS at all service owned and operated water systems at a minimum of every three years.

The EPA’s health advisory states that if water sampling results confirm that drinking water contains PFOA and PFOS at individual or combined concentrations greater than the Health Advisory, water systems should quickly undertake additional sampling to assess the level, scope, and localized source of contamination to inform next steps.

Water Quality Data Table

The following table lists all of the drinking water contaminants detected at MCAS Iwakuni during this reporting period. The presence of contaminants does not necessarily indicate that the water poses a health risk. All substances detected in MCAS Iwakuni’s drinking water meet DoD JEGS requirements.

CONTAMINANT (UNITS)	AL MCL	Highest Level Detected	Lowest Level Detected	Year	Possible Source of Contamination	Violation
INORGANIC CHEMICALS / METALS/ VOC’s/ HYDROCARBONS						
Fluoride (ppm)	4	0.80	0	2022	Water additive which may promote dental health.	No
Total Nitrite and Nitrate (ppm)	10	0.28	0.24	2022	Runoff from fertilizer use, leaking from septic tanks, sewage, and erosion of natural deposits.	No
Toluene (ppb)	1000	0.069	ND	2022	Aromatic hydrocarbon used as an industrial feedstock and a solvent.	No

CONTAMINANT	AL/ MCL/ MRDL	RAA	Highest Level Detected	Lowest Level Detected	Year	Possible Source of Contamination	Violation
DISINFECTION BYPRODUCTS							
Residual Chlorine (ppm)	4	N/A	0.84	<0.05*	2022	Water additive used to control Microbes.	No*
Total Trihalomethanes (ppb)	80	16.81	34	0.50	2022	Byproduct of drinking water disinfection.	No
Haloacetic Acids (HAA5) (ppb)	60	8.65	10	2.0	2022	Byproduct of drinking water disinfection.	No

Summary of Compliance Discrepancies

Discrepancy	Consumer Health Impact	Corrective Action
*Low chlorine residual has been detected at a distant location from the pump house.	None – chlorine is added to drinking water to eliminate bacteria. No bacteria have been detected.	Flushed water pipes to increase the amount of fresh water containing higher levels of chlorine.

Abbreviations and Definitions:

AL: (Action Level): The concentration of a contaminant in water that establishes the appropriate treatment for a water system.

MCL: (Maximum Contaminant Level): The highest level of a contaminant allowed in drinking water.

MRDL: (Maximum Residual Disinfectant Level): The level of a disinfectant added for water treatment measured at the consumer's tap, which may not be exceeded without the unacceptable possibility of adverse health effects.

ND: Not Detected.

ppb: parts per billion or micrograms per liter. One ppb is the equivalent of one drop of impurity in 500 barrels of water or 1 cent out of \$10 million (Navy PFAS Regulatory Framework).

ppt: parts per trillion or nanograms per liter. One ppt is the equivalent of one drop of impurity in 500,000 barrels of water (Navy PFAS Regulatory Framework).

ppm: parts per million or milligrams per liter.

RAA- Running Annual Average.

Constituent	Frequency
pH, Conductivity, Turbidity, Chlorine Residue, Water Temperature, and Water Pressure	Hourly
Fluoride and Turbidity	Daily
Disinfection byproducts (Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5))	Quarterly
Total Coliform	Monthly
Lead, Copper and Inorganic Chemicals (excluding Nitrate, Nitrite)	Annually
Lead in Priority Areas (LIPA)	Once every 5 years
Nitrate and Nitrite	Quarterly
Synthetic Organic Chemicals	Quarterly
PCBs, Herbicides, and Pesticides	Once every 3 years
Radionuclides	Once every 4 years
Asbestos	Once every 9 years
Per- and polyfluoroalkyl substances (PFAS)	Once every 3 years

The table on page four lists constituents detected during January-June 2022 water sampling. Only those constituents detected are listed. The presence of a contaminant does not necessarily indicate the water poses a health risk. As such, MCAS Iwakuni's drinking water is deemed fit for human consumption. For more information on this report or water quality in general, please contact the MCAS Iwakuni Environmental Division, Water Program Manager- at 253-5388 or david.r.campbell1@usmc.mil.